GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2026/School/WZ/42 Dated: 30/03/2026

FIRE SAFETY CERTIFICATE

Certified that the Shivshakti Vidyapeeth located at Khasra No-281-284, Lakhmi Enclave Extd Lal Dora, Alipur Delhi-110036 comprised of Ground & 02 upper floors only owned/ occupied by the Shivshakti Vidyapeeth have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 17/03/2026 in the presence of Sh. Shivam Mann and that the building/premises is fit for occupancy Class **"Group B Educational (School) for single block comprised of ground & 02 upper floors only"** with effect from 30/03/2026 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/03/2026 at New Delhi

30/03/26
(S.K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director of Education, Government of NCT of Delhi. Old Secretariat, Delhi–110054.
2. The Principal, Shivshakti Vidyapeeth located at Lakhmi Enclave Extd Lal Dora, Alipur Delhi-110036.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

V Singh
MANAGER
SHIVSHAKTI VIDYAPEETH
LAKHMI ENCLAVE Extd. LAL DORA
ALIPUR , DELHI-110036

Pallavi
PRINCIPAL
SHIVSHAKTI VIDYAPEETH
LAKHMI ENCLAVE Extd. LAL DORA
ALIPUR , DELHI-110036